



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 10/13/09

Code 50.10.8.4-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title <b>Indiana Residential Code</b>		Edition <b>2009</b>
Section number and title <b>R606.10 Anchorage</b>		Page <b>1</b>
Proponent <b>SW Indiana Builders and Officials</b>	Title	
Address <b>2175 N Cullen Ave Evansville, IN 47715 Room 310, Civic Center Complex, Evansville, IN 47708</b>		Phone <b>812-479-6026 &amp; 812-436-7868</b>
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<b>Delete and replace as follows: "Above grade masonry walls shall be anchored to floor, roof, and foundation systems in accordance with details of Figure R606.10(1). In SDC C1, above grade masonry walls shall be anchored to floor, roof and foundation systems in accordance with details of R606.11(1) and Figure R606.11(2). Below grade foundation walls shall comply with Section R403 and R404."</b>		
REASON		
<b>This amendment is part of the Seismic Package supported by home builders and building officials in the area, and is consistent to the existing standards. <i>Fiscal impact: As this seismic package is parallel to existing standards, no impact is expected.</i></b>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		